



Health & Safety Alert

Damage to Uni-Pillar

SUMMARY

During a site inspection it was found that a vehicle had struck a pillar causing damage to the base, and the pillar to lean over. External damage to pillars can create safety issues if the internal components are damaged as well.

All builders, contractors, and residents have a duty of care to report incidents such as this Eglinton Village Energy (24/7 hotline 1800 920 062) if assets are damaged so the situation can be assessed as soon as possible. This includes (but isn't limited to) cables, pillars, streetlights and other network infrastructure.



In this instance, the damage was not reported to Eglinton Village Energy.

ISSUE

- Vehicle damage to Uni-Pillar
- Damage not reported to Eglinton Village Energy (24/7 hotline 1800 920 062)

ACTION REQUIRED

After receipt of this Health & Safety Alert:

- All builders to forward this alert to your subcontractors and for it to be raised at site toolbox meetings
- Report damage to assets to Eglinton Village Energy on 1800 920 062

For all further enquires or information please contact the Eglinton Village Energy Customer Service team at: CustomerService@eglingtonvillageenergy.com.au

Issue Date: 01/05/2026	Health & Safety Alert - Connected Energy Damage to Uni-Pillar	PAGE 1 of 1
---------------------------	--	-------------